

ElectroFin® coated coil maintenance record

Installation site _____

Installation date _____

Unit model # _____

Unit location _____

Unit serial # _____

Customer _____

Year 20____	Ambient temp (°F)	Surface debris removed	Coil cleaned	Approved cleaner used	Potable water backwash rinse	Potable water frontwash rinse	Chlorides removed	Comments
Jan								
Feb								
Mar								
Apr								
May								
Jun								
Jul								
Aug								
Sep								
Oct								
Nov								
Dec								

The following cleaning agents have been approved for use on ElectroFin coated coils to remove mold, mildew, dust, soot, greasy residue, lint and similar particulate without harming the coated surfaces:

Cleaning Agent	Reseller	Part #
Enviro-Coil Concentrate	HYDRO-BALANCE CORPORATION P.O. Box 730 Prosper, Texas 75078 (P)800.527.5166 (F) 972.394.6755	H-EC01

Recommended chloride remover
CHLOR*RID Distributed by Luvata Tel: 844 782 2100 Fax: 813 689 4630

Failure to maintain coil coatings using the ElectroFin coil cleaning procedures and to record such maintenance on this record will void the ElectroFin warranty for coil coatings.